



SOUTHERN POWER DISTRIBUTION COMPANY OF T.S.LTD.

6-1-50, Corporate Office, Mint Compound, Hyderabad - 500 004

O/o. The Chief Engineer (Commercial),
TGSPDCL, Ground Floor, Corporate Office,
Mint Compound, Hyderabad.

Circular Memo No. CE (Comml)/SE(C)/DE(EoDB)/ADE-EoDB/D.No. 2567/24, Dt 28-09-2024

Sub: CE/Commercial/TGSPDCL– Ease of Doing Business Reforms – Business Reform Action plan,2024- Reform No.178-Regarding.

Ref: Business Reforms Action Plan- 2024 released by The Department for Promotion of Industry and Internal Trade (DPIIT), Ministry of Commerce and Industry, Gov. of India

<<<>>>

In compliance with the Ease of Doing Business (EoDB), the DPIIT has mandated in Business Reforms Action Plan 2024, Reform No.178, that the Telangana Southern Power Distribution Company Limited (TGSPDCL) has to

- i. Mandate external electricity installation works typically carried out by a licensed professional/ company
- ii. Mandate the frequency of the following:
 - a. Inspection by contractor/company that performed external installations
 - b. Issuance of certificate of compliance by contractor/company
 - c. Check quality of external installation works by contractor/company
- iii. Mandate the quality check or final inspection by a third party to ensure the quality and safety of external electricity installations

In this regard, all the field officers are instructed to follow:

- i. Mandate external electricity installation works typically carried out by a licensed professional/ company

➤ ***The electrical installation works are being carried out by a contractor licensed from CEIG as per the S.P.O.O (O&M) Ms.No.250, Dt:13-05-2016 and the Contractor registration is mandatory for all turnkey works being carried out by the consumers.***

- ii. Mandate the frequency of the following:

a. Inspection by contractor/company that performed external installations

➤ ***1ST Inspection: Initial PEG marking shall be taken to start with the work, to locate and indicate the area of work. i.e. Pole/Pit marking for stubs of the tower/other pole erections.***

➤ ***2nd Inspection: After erection of pole/tower during stringing of line or laying of UG cable in order to maintain the clearances in case of overhead line and depth of the trench for laying of UG cable.***

➤ ***3rd Inspection: The contractor/company must carry out the final inspection of work to ensure that the work is completed as per the sanctioned estimate.***

b. Issuance of certificate of compliance by contractor/company

➤ ***The contractor/company should issue work completion certificate after completion of work in full shape.***

c. Check quality of external installation works by contractor/company

➤ ***The execution of line work is to be carried out by the contractor/company as per REC Specifications and Construction Standards, Dated 30.07.1994.***

iii. Mandate the quality check or final inspection by a third party to ensure the quality and safety of external electricity installations

➤ ***M/s. ASCI is appointed as third party inspection agency for final inspection of works carried out for new Industrial applications (HT-I & LT-III). The consumer has to bear the third party inspection charges which are detailed below.***

a) For each HT service @ Rs.9,500/-(excluding GST)in the GHMC area

b) For each HT service @ Rs.11,500/-(excluding GST)in the remaining area of TGSPDCL.

c) For each LT service @ Rs.4,000/-(excluding GST)in the GHMC area

d) For each LT service @ Rs.5,000/-(excluding GST)in the remaining area of TGSPDCL


CHIEF ENGINEER

COMMERCIAL, TGSPDCL, HYDERABAD

To:

All the Superintending Engineers/Operation/.....

Copy to:

The Chief General Manager/Operation/Metro Zone, Medchal Zone Rangareddy Zone and Rural Zone

The Chief General Manager/IPC, RAC, Revenue, Finance, O&M & P&MM

Copy submitted to:

The Director/Commercial/TGSPDCL

The Divisional Engineer/Technical to CMD/TGSPDCL