

ANNEXURE-1 : Clarifications
Name of the Firm: M/s Schneider

Bid no. :		Chief General Manager/Projects/TGSPDCL/ SCADA: 01/2024-25				
S.No	Section	Clause name	Page	Subject in the Specification	Clarifications sort by Schneider	TGSPDCL Remarks
1	Section -I Notice inviting bids	Notice for inviting the bids	5	And integrate to the existing SCADA system for Integration of all the 112 nos. non-integrated substations and for integration of 103 numbers 11kV feeders in already integrated substations (existing SCADA system in the utility).	Usualy as a bidder / equipment OEM ,we shall provide support for integration to SCADA Sytem for RTU and IED relays. As the Sofiware is not in the scope of tender, request you to kindly confirm the support from software OEM to complete the integration shall be in the scope of TGSPDCL and Integration support from field equipments in the scope of bidder.	No change. The responsibility of integration of existing RTU with new equipments is in the scope of TGSPDCL. However, the extraction of ICD files of IED relays and coordinating for configuration in the existing RTU is in the bidder scope.

ANNEXURE-1 : Clarifications
Name of the Firm: M/s Schneider

Bid no. :		Chief General Manager/Projects/TGSPDCL/ SCADA: 01/2024-25				
S.No	Section	Clause name	Page	Subject in the Specification	Clarifications sort by Schneider	TGSPDCL Remarks
2	Section -I Notice inviting bids	Notice for inviting the bids	5	Facilities management services for maintaining infrastructure, post successful completion of acceptance tests for a period of five years from the date of completion of acceptance.	Request you to please remove the scope of FMS for the entire system. We shall provide FMS for the field equipments that are connected to the SCADA control centre as the software is not in the scope of bidder.	No change. The scope of work is mentioned in the Page No.5 duly mentioning about FMS work.
3	Section -III Instructions to Bidders (ITB)	3(b).Interchangeability	15	All similar materials and removable parts of similar equipment will be interchangeable with each other. A specific confirmation of this should be furnished in the bid.	Our components are free to make interchangeable. However interchangeable is in the scope of End user(TGSPDCL). Kindly confirm.	No Change. The confirmation from bidder is required, if any equipment is interchanged in future the SCADA operation should not effect.

ANNEXURE-1 : Clarifications
Name of the Firm: M/s Schneider

Chief General Manager/Projects/TGSPDCL/SCADA: 01/2024-25

S.No	Section	Clause name	Page	Subject in the Specification	Clarifications sort by Schneider	TGSPDCL Remarks
4	Section -VI Qualification Requirements	Qualification Requirements	44	<p align="center">Financial</p> <p>i. The total turnover shall be Rs.20 Crores during the last five years certified by CA. ii. Net Worth for the last three Financial Years should be positive. iii. The bidder should have successfully executed at least two Turnkey contract of SCADA System in last 10 years in INDLIA in any power utility/ Government organizations. Limited companies for Electrical distribution system. The Cumulative value of contracts shall not be less than Rs. 10 Cr for the total contracts executed during the last 5 years. iv. Liquid assets and credit facilities of not less than 25% of the bid value (credit lines/ letter of credit/ solvency certificates from Banks, etc – usually the equivalent of the estimated cash flow for 3 months in peak work period).</p>	Request you to confirm 20Cr for the cumulative of 5 years.	No Change.